



NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 - CPR - 0723

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Wireless combined smoke and heat detector JA-150ST

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

JABLOTRON ALARMS a.s.
Pod Skalkou 4567/33, 466 01 Jablonec nad Nisou, Czech Republic

and produced in the manufacturing plant

VAT No. 5 4403017266193470

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-5: 2017 + A1: 2018, EN 54-7: 2018, EN 54-25: 2008, EN 54-25: 2008/AC: 2010,

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on December 01st, 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, December 01st, 2020

Marek Hudák Director NB

053825

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 1 / 2 FCO 425-13 Rev.1

Annex to Certificate No. 1293 - CPR - 0723 from December 01st, 2020

Technical specifications

This product is part of Jablotron JA-100. It is used to detect fire hazards in commercial or residential interiors. It is designed for installation in industrial environments. The detector communicates wirelessly and is powered by three AA batteries.

It consists of two separate detectors - optical smoke detector and temperature detector. Optical smoke detector operates on the principle of scattered light and is very sensitive to larger particles, which are dense smokes, is less sensitive to small particles from burning liquids such as alcohol. Therefore, the built detector temperature, which has a slower response, but the fire rapidly rising heat with little smoke detector that responds to temperatures much better. The microprocessor performs a digital analysis of these variables, which ignificantly increases resistance to false alarms.


Category according to EN 54-5: A2

| | Harmonised technical specification | | | 7 |
|---|--|---|---|-------------|
| Essential characteristics | EN 54-25:2008, EN 54-25:2008/ AC:2010 | EN 54-5: 2017+ A1: 2018 | EN 54-7: 2018 | Performance |
| Operational reliability | cl. 4.2.1, 4.2.3- 4.2.7, 5.3, 5.4, 6.7, 8.2.2, 8.2.4, 8.2.7-8.2.9, 8.3.1, 8.3.2, 8.3.4-8.3.6 | cl. 4.2.1, 4.2.2 4.2.3=N/A 4.2.4, 4.2.5 4.2.6=N/A 4.2.7 | cl. 4.2.1, 4.2.2=N/A 4.2.3, 4.2.4 4.2.5=N/A 4.2.6 - 4.2.8 | Pass |
| Nominal activation conditions / Sensitivity | cl. 4.1, 4.2.2, 5.2, | cl. 4.3.1 - 4.3.3 4.3.4=N/A 4.3.5, 4.3.6 | cl. 4.3.1 to 4.3.3 | Pass |
| Response delay (response time) | 8.3.7, 8.2.3, 8.2.6 | cl. 4.4.1=N/A 4.4.2=N/A | cl. 4.4.1, 4.4.2 | Pass |
| Performance parameters under fire conditions | | | cl. 4.6 | Pass |
| Tolerance to supply voltage | - | cl. 4.5.1 | cl. 4.5 | Pass |
| Durability of Nominal activation condition / Sensitivity: Temperature resistance | cl. 8.3.9-8.3.11 | cl. 4.6.1.1, 4.6.1.2=N/A | cl. 4.7.1.1, 4.7.1.2 | Pass |
| Durability of Nominal activation condition / Sensitivity: Humidity resistance | 8.3.12=N/A cl. 8.3.13, 8.3.14 | cl. 4.6.2.1, 4.6.2.2 | cl. 4.7.2.1, 4.7.2.2 | Pass |
| Durability of Nominal activation condition / Sensitivity: Corrosion resistance | cl. 8.3.15 | cl. 4.6.3 | cl. 4.7.3 | Pass |
| Durability of Nominal activation condition / Sensitivity: Vibration resistance | cl. 8.3.16-8.3.19 | cl. 4.6.4.1 - 4.6.4.4 | cl. 4.7.4.1 - 4.7.4.4 | Pass |
| Durability of Nominal activation condition / Sensitivity: Electrical stability | cl. 8.3,20 | cl. 4.6.5 | cl. 4.7.5 | Pass |

History of certification

| No. | Certificate No. | Description | Date of issue |
|-------|-----------------|-----------------------------|----------------------------------|
| 1/1// | 1293-CPR-0508 | Original certificate issued | December 14 th , 2015 |
| 2 | 1293-CPR-0723 | New editon of standards | December 01 st , 2020 |

Nová Dubnica, December 01st, 2020



Marek H u d á k Director NB